

CHARLES J. VOLPE, JR PURCHASING AGENT

(203) 797-4571 PHONE (203) 796-1527 FAX c.volpe@danbury-ct.gov

July 18, 2016

ADDENDUM #3

To

Bid #06-15-16-06 "Replacement of Westconn Tank"

This addendum shall be part of the Purchasing documents for the above captioned Bid. This addendum is to be acknowledged by the bidder by signing as provided below and returning with the bidder's proposal.

CLARIFICATION:

Insert the following paragraph before the first paragraph of Section 9.7, Miscellaneous, of the Detailed Specifications:

New equipment except for the chlorine analyzer shall be installed at the locations of the existing equipment and use the existing conduit and wiring. Conduit and wiring for the chlorine analyzer shall be run from the power distribution cabinet in the pump room to the chlorine analyzer. Less than 100 feet of new ¾-inch conduit will be required. Wiring shall be two conductors and one ground, #12 AWG, Type THHN/THWN, with 600 volt insulation.

BID DUE DATE: Remains the same: 10:00 AM, Thursday, July 21, 2016

Receipt of the	addendum is hereby acknowledged.
Bidder	
Signature	
Title	
Date	

Charles J. Volpe, Jr. Purchasing Agent City of Danbury